Owner / Applicant Information						
Jim Wolfe						
University of Southern Indiana						
8600 UNIVERSITY BLVD						
EVANOVII LE IN 17740						
EVANSVILLE IN 47712						
Phon∈ 8124914120						
Email JWOLFE2@USI.EDU						
Submitter Information						
Roger Lehman						
RLehman Consulting						
1220 N Red Bank Rd						
Evansville IN						
Phon∈ 8125890331						
Email rlehmanconsulting@gmail.com						
Project Information						
USI Natatorium						
8600 University BLVD						
account of the control of the contro						
Evansville IN 47712						
Evansville IN 47712 County VANDERBURGH						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy						
Evansville IN 47712 County VANDERBURGH						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy Project Status U F=Filed U or Null=Unfiled						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? No						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? No Violation Issued by: NA Local Building Official Phone: 8124367867 Email: rbeane@evansville.in.gov						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? No Violation Issued by: NA Local Building Official Phone: 8124367867 Email: rbeane@evansville.in.gov Local Fire Official						
Evansville IN 47712 County VANDERBURGH Project Type New Addition Y Alteration Existing Change of Occupancy Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? No Violation Issued by: NA Local Building Official Phone: 8124367867 Email: rbeane@evansville.in.gov						

Variance Deta	<u>ils</u>						
Code Name:	Other Code (Not in the list provided)						
	2014 IBC Table 706.4						
Conditions:	A4 Natatorium will be separated from existing A3 Physical Activities building by 2 hr. fire barrier in lieu of 3 hr. fire wall.						
DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:							
	1=Non-compliance with the rule will not be adverse to the public health, safety or w						
2	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).						
Facts: New fully sprinkled Type II building which houses new swimming pool/locker room fa has about 45' of exterior wall connected to existing Type IIB fully Sprinkled masonry v							
	physical activities building. Sprinkler density will be increased in adjacent pool mechanical room which is partially						
	located along wall in question and water heater service room.						
	Masonry walls will be provided in new building at connecting location.						
<u>DEMONS</u>	TRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:						
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.						
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.						
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.						
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure						
Facts:	Construction of self supporting 3hr fire wall will result in more costly construction than is justifiable considering the uses of the 2 structures and the lack of serious fire hazard coming from new natatorium.						

Variance Deta	<u>ils</u>						
Code Name:	e: Other Code (Not in the list provided)						
	2014 IBC 903.2.1.3						
Conditions:	16,000 sq. ft. A3 Type IIB sprinkled natatorium will not have sprinklers over pool water area						
DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:							
	1=Non-compliance with the rule will not be adverse to the public health, safety or w						
2	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).						
Facts:	Pool is used year round and will not have any combustibles. Remainder of deck and all other areas will be fully covered to NFPA 13 standards. Sprinkler density will be increased in pool pump and heater room.						
	Spectator seating 220.						
DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:							
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.						
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.						
Y	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.						
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure						
Facts:	Servicing sprinkler systems over pool would require draining pool which is used year round. Increasing protection in hazardous areas is more cost and safety beneficial than protecting pool water.						