Owner / Applicant Information		
David Leazenby		
106 North, LLC		
460 VIRGINIA AVENUE		
INDIANAPOLIS IN 46203		
Phon∈ 3176727920		
Email DAVID.LEAZENBY@ONYXANDEAST.COM		
Submitter Information		
Timothy Callas		
J & T Consulting, LLC		
8220 Rob Lane		
Indianapolis IN		
Phon∈ 3178894300		
Email tcallas@jtconsult.us		
Zinaii todiido o jioo nodii.do		
<u>Designer Information</u>		
Todd William Rottmann		
Rottmann Collier Architects, Inc.		
155 East Market Street		
Indianapolis IN		
Phon∈ 3177212724		
Email todd@rottmanncollier.com		
Project Information		
106 North		
106 East North Street		
INDIANAPOLIS IN 46204		
County MARION		
Project Type New Y Addition Alteration Existing Change of Occupancy		
Project Status F F=Filed U or Null=Unfiled		
IDHS Issued Correction order? No Has Violation been Issued? No		
Violation Issued by: NA		
Local Building Official  Phono: 217227EE44		
Phone: 3173275544 Email: planreview.class1@indy.gov Local Fire Official		
Phone: 3173275544 Email: Margie.Bovard@indy.gov		

	<b>-</b>
Variance	Details

Code Name: Other Code (Not in the list provided)

2014 IBC 905.3.1

Conditions: A new 4-story R-2 Occupancy, Type VA construction apartment building # 1 & #2 that has

private stairs within each dwelling unit will not be provided with Class I standpipes.

## DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

2 = Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: 1. The building is protected with a fire suppression system throughout per NFPA 13R, 2010 Edition

2. The building will have a fire alarm system as required; however will be actuated by either sprinkler flow or manual pull stations.

Only one of the two methods is required.

3. Each unit has an exterior door that leads from the interior dwelling unit stair. At each of these locations a strobe/horn will be

placed that is visible from the main access road leading to the building. The fire alarm system will be zoned to identify which

dwelling unit is in alarm mode the strobe/horn will actuate at the units entry door.

## DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure
Facts:	The owner's undue hardship involves the stairs are private stairs with no access to the fire department, thus cost is not justified. Additionally the intent of the code is to provide a safe environment for the fire fighters in rated stair enclosures to use standpipes. The stairs are not enclosed rated stairs. There are no common use areas in the building such as common stairs or corridors.