

Owner / Applicant Information

Todd Buerger  
Butler University  
451 WEST 52ND STREET

INDIANAPOLIS IN 46208

Phone 3179408466

Email TBUERGER@BUTLER.EDU

Submitter Information

Ralph Ralph Gerdes Consultants Gerdes  
Ralph Gerdes Consultants, LLC  
5510 S. East St.

Indianapolis IN

Phone 3177873750

Email Ralph@rgc-codes.com

Designer Information

Alan Tucker  
CSO Architects  
8831 Keystone Crossing

Indianapolis IN

Phone 3178487800

Email atucker@CSOinc.net

Project Information

Butler University Irwin Library  
4553 Clarendon Road

Indianapolis IN 46208

County MARION

Project Type New ☐ Addition ☐ Alteration ☐ Existing ☒ Change of Occupancy ☐

Project Status ☒ U F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☒ No Has Violation been Issued? ☒ yes

Violation Issued by: LFD

Local Building Official

Phone:

Email:

Local Fire Official

Phone:

Email:

Variance Details

Code Name: Other Code (Not in the list provided)

2014 InFC, 3311.2

Conditions: North exit of Irwin Library will be closed for about one (1) year during construction of new Lacy School of Business. New building will connect to three (3) story Library at First and Second Floor. Temporary closure of north stair will result in dead end corridors, common path of travel issues, remote exiting, use of open 3 story stair, etc.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

☐ 1

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: 1. Appropriate signage will be provided.  
2. Enclosed south stair and open center stair will be used for exiting.  
3. One (1) accessible entrance will be maintained.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

☒ Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

☒ Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

☒ Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

☐

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: New Lacy School of Business will be constructed next to Irwin Library. Two (2) level pedestrian walkway will connect to Irwin Library. This new construction will require temporary closing of the existing north exit stair and discharge.