Owner / Applicant Information		
Ann Luther		
Phoenix Theatre		
749 N. PARK AVE.		
INDIANAPOLIS IN 46202		
Phon∈ 3172949300		
Email PROGRAMCHAIRISPE@GMAIL.COM		
Submitter Information		
Edwin Rensink		
RTM Consultants Inc		
6640 Parkdale Place		
Indianapolis IN		
Phon∈ 3173297700		
Email rensink@rtmconsultants.com		
Designer Information		
WILLIAM Browne, Jr., FAIA		
RATIO Design		
101 S. Pennsylvania Street		
Indianapolis IN		
Phon∈ 3176334040		
Email bbrowne@ratiodesign.com		
Enail bbrowneeraliodesign.com		
Project Information		
Phoenix Theatre 705 N Illinois St		
705 N IIIII 1015 St		
INDIANAPOLIS IN 46204		
County MARION		
Project Type New Y Addition Alteration Existing Change of Occupancy		
Project Status F F=Filed U or Null=Unfiled		
IDHS Issued Correction order? No Has Violation been Issued? yes		
Violation Issued by: LBD		
Local Building Official		
Phone: 3173275544 Email: planreview.class1@indy.gov		
Local Fire Official		
Phone: 3173275544 Email: margie.bovard@indy.gov		

Variance Details		
Code Name:	Other Code (Not in the list provided)	
	1011.4, 2014 IBC	
Conditions:	Tactile exit signs have been cited at exterior exit doors. The code states that they are required adjacent to each door to an area of refuge, an exterior area for assisted rescue, an exit stairway, an exit ramp, an exit passageway and the exit discharge.	
	The owner contends that they are not required at exterior exit doors per code language.	
DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:		
	1=Non-compliance with the rule will not be adverse to the public health, safety or w	
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).	
Facts:	1. The exterior exit door is an exit component per IBC definition, it is not part of the exit discharge per IBC definition. Sec. 1011.3 does not enumerate exterior exit doors as requiring tactile signs. It does, however, enumerate doors to egress stairways. 2. A No Variance Required ruling was issued by the Commission for an identical variance in the case of 18-02-43c.	
DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:		
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.	
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.	
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.	
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure	

Hardship is providing tactile signs at locations other than those specified by the IBC.

Facts: