

Owner / Applicant Information

Mark B Mynhier
MB Mynhier, Architect
7455 S STATE ROAD 5

SOUTH WHITLEY IN 46787

Phone 2606093402

Email MBM@MBMYNHIER.COM

Submitter Information

Mark B Mynhier
MB Mynhier, Architect
7455 S State Road 5

South Whitley IN

Phone 2606093402

Email mbm@mbmynhier.com

Designer Information

Mark B Mynhier
MB Mynhier, Architect
7455 S State Road 5

SOUTH WHITLEY IN

Phone 2606093402

Email mbm@mbmynhier.com

Project Information

Cleveland Amish School
5700 West Whitley Road

South Whitley IN 46787

County WHITLEY

Project Type New ☐ Addition ☐ Alteration ☐ Existing ☐ Change of Occupancy ☐

Project Status ☐ F F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☐ yes Has Violation been Issued? ☐ No

Violation Issued by: NA

Local Building Official

Phone: Email:

Local Fire Official

Phone: Email:

Variance Details

Code Name: 2014 IBC
2902.1

Conditions: This is a small Amish school. The drinking fountain required by table 2902.1 will not be installed.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

2

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: Bottled water will be provided for occupants.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

☐

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: This is a small rural Amish school with neither electricity or water service to serve a drinking fountain available on site.

Variance Details

Code Name: Other Code (Not in the list provided)
907.2.3

Conditions: This is a small Amish school with an occupant load of less then 70. The manual fire alarm system required by Section 907.2.3 will not be installed.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

2

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: Provide interconnected, long life battery smoke and heat detectors throughout the building.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: -This small two-room school will have a fully operational interconnected smoke and heat detector/alarm system throughout the building. Adequate notice to evacuate the building will be provided via this system. The only difference between the system proposed and the required system is the addition of a manual pull station at the exit doors. Given the small size of the building these pull stations are not necessary.

