| Owner / Applicant Information | |
|---|--|
| Mike Wickersham | |
| Randolph County, Indiana | |
| 100 SOUTH MAIN STREET | |
| WINCHESTER IN 47394 | |
| Phon∈ 7655846700 | |
| Email MWICKERSHAM@RANDOLPH.IN.GOV | |
| Email WWICKERSHAWERANDOLI TI.IIV.GOV | |
| Submitter Information | |
| Christina RTM Consultants Collester | |
| RTM Consultants, Inc. | |
| 6640 Parkdale Place | |
| Indianapolis IN | |
| Phon∈ 3173297700 | |
| Email collester@rtmconsultants.com | |
| Designer Information | |
| Bernard Trauner | |
| Paul I. Cripe, Inc. | |
| 3939 Priority Way S Drive, | |
| | |
| Indianapolis IN | |
| Phon∈ 3177066495 | |
| Email dtrauner@cripe.biz | |
| | |
| Project Information | |
| Randolph County Highway Department Facility | |
| 2250 S US 27 | |
| | |
| Winchester IN 47394 | |
| County RANDOLPH | |
| Project Type New Y Addition Alteration Existing Change of Occupancy | |
| Project Status U F=Filed U or Null=Unfiled | |
| IDHS Issued Correction order? Has Violation been Issued? | |
| <u>Violation Issued by:</u> NA | |
| Local Building Official | |
| Phone: 7655844411 Email: bldcom01@randolph.in.gov | |
| Local Fire Official | |
| Phone: 7655844411 Email: dwayne.wiggans@winchester- in.gov | |
| | |
| | |

| Variance Details | | |
|--|--|--|
| Code Name: | Other Code (Not in the list provided) | |
| | 2014 IBC 903.2.9.1 (4.) | |
| Conditions: | A County vehicle maintenance repair garage will have a fire area Exceeding 5,000 square feet | |
| | in area. Code limits the fire area of buildings used for the storage or repair of commercial vehicles to 5,000 square feet. Buildings with fire areas over 5,000 square feet must be sprinklered or divided into fire areas less than 5,000 square feet by 3-hour fire barriers. | |
| DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED: | | |
| | 1=Non-compliance with the rule will not be adverse to the public health, safety or w | |
| 2 | 2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific). | |
| Facts: | 1. The office area will be separated from the 9,480 Sf maintenance bay by a 2-hour Fire Barrier. | |
| | 2. Other areas within the Maintenance Bay will be separated by one hour walls as indicated on the drawings. | |
| | 3. A fire alarm system will be installed in the building. | |
| DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE: | | |
| Υ | Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services. | |
| | Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure. | |

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

architecturally or a historically significant part of the building or structure

Compartmentalizing is the most cost effective option however would basically render the

project would require a Fire Pump and Water storage tank at a cost of approximately

space useless to the owner and because the water source for the building is from a well, this

Imposition of the rule would prevent the preservation of an

Facts:

\$190,000.00.