Owner / Applicant Information
Angela Allen
Silver Coin Wedding Barn
5040 GENTLE WAY
LAFAYETTE IN 47905
Phon∈ 7654792147
Email AMTTRUCKING@AOL.COM
Email AWT TROCKING@AGE.COM
Submitter Information
Christina RTM Consultants Collester
RTM Consultants, Inc.
6640 Parkdale Place
Indianapolis IN
Phon∈ 3173297700
Email collester@rtmconsultants.com
Designer Information
Kelly Good
KJG Architecture
527 Sagamore Pkwy West
West Lafayette IN
Phone 7654974598
Email kelly@kjgarchitecture.com
Project Information
Silver Coin Barn
5181 N State Road 39
Frankfort IN 46041
County CLINTON
Project Type New Y Addition Alteration Existing Change of Occupancy
Project Status U F=Filed U or Null=Unfiled
IDHS Issued Correction order? Has Violation been Issued?
Violation Issued by: NA
Local Building Official  Phono: 7452374920 Email: mtimmons@clintonco.com
Phone: 7653376830 Email: mtimmons@clintonco.com Local Fire Official
Phone: 7653376830 Email: station9@centurylink.net

Variance Deta	ile						
Code Name:							
code Name.	903.2.1.2, 2014 IBC						
Conditions:	An automatic sprinkler system will not be provided in the new event center, classified as A-2 Occupancy. A sprinkler system is required due to exceeding 5,000 sq ft (approximately 8,000 sq ft actual) and an occupant load of 100 or more (approximately 400 calculated occupant load).						
	The building will be Type VB Construction.						
<u>DEMON</u>	NSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:						
	1=Non-compliance with the rule will not be adverse to the public health, safety or w						
2	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).						
Facts:	1. The building will be provided with an automatic fire alarm system, with a shunt trip provided to shut down the sound system upon system actuation.						
	2. The building will be provided with smoke detection throughout (not required by code) tied to the fire alarm system.						
	3. Two exterior exits are provided as required per code with panic hardware, with a maximum travel distance of less than 75 feet to an exit from the event space. additionally 13 pairs of french doors to a patio that connects to the public way are provided with standard door hardware reducing travel distance to 25 feet or less throughout the assembly area.						
	4. The kitchen does not contain commercial cooking equipment, and is for warming only.						
	5. Previous similar variances have been granted for new 1-story A-2 Occupancy buildings in rural locations including 18-02-39, 18-01-24, 17-08-65, 17-08-55, 17-07-32, 16-11-31, 16-06-07,						
	16-05-45, 16-04-51, 16-02-25, 16-01-24, 15-10-22, 15-04-41, 14-10-19, 14-03-33, 13-03-33, and 12-12-21.						

## DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure
Facts:	A water supply capable of supplying an automatic sprinkler system is not available to the site.