

Owner / Applicant Information

Chris Teeter
DT Retail Properties, LLC
500 VOLVO PARKWAY

CHESAPEAKE VA 23320
Phone 7573215000
Email CTEETER@DOLLARTREE.COM

Submitter Information

Linda Snapp
Clark Geer Latham & Associates
3901 Springhill Ave

Mobile IN

Phone 2513447073
Email lsnapp@cglengineers.com

Designer Information

Linda G. Levin Snapp
Clark Geer Latham and Associates, INC
3901 Springhill Ave

Mobile AL

Phone 2513447073
Email lsnapp@cglengineers.com

Project Information

Dollar Tree Goshen IN
2323 Lincolnway E

GOSHEN AL 46526

County ELKHART

Project Type New ☐ Addition ☐ Alteration ☐ Existing ☐ Change of Occupancy ☐

Project Status ☐ F F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☐ No Has Violation been Issued? ☐ No

Violation Issued by: NA

Local Building Official

Phone: Email:

Local Fire Official

Phone: Email:

Variance Details

Code Name: Other Code (Not in the list provided)
903.2.11.1.2

Conditions:

Building is not required to be nor is sprinkled.
The building is 81'-4" deep and therefore is required to have openings in 2 sides in each 50 linear feet

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

- 2

1=Non-compliance with the rule will not be adverse to the public health, safety or w
- 2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts:

The building is equipped with a fire alarm system

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

- ☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
- ☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
- Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
- ☐

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts:

The plans were approved without this opening. The building construction is complete and in order to add this opening there would be structural modifications required which would cause a hardship. This is a PEMB with structural girts 24" o.c. that run horizontal.
The sheetrock would have to be removed and the girts cut and modified.