

Owner / Applicant Information

bsn sports bsn sports
BSN Sports
5349 W. 76TH STREET

INDIANAPOLIS IN 46268

Phone 3179601934

Email BTURNER@BSNSPORTS.COM

Submitter Information

Brent Turner
BSN Sports
5349 W 76th Street

Indianapolis IN

Phone 3179601934

Email bturner@bsnsports.com

Project Information

Install 17 new HVLS Fans
5349 W 76th Street

Indianapolis IN 46268

County MARION

Project Type New ☐ Addition ☐ Alteration ☒ Existing ☐ Change of Occupancy ☐

Project Status ☒ F F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☒ yes Has Violation been Issued? ☒ yes

Violation Issued by: LFD

Local Building Official

Phone:

Email:

Local Fire Official

Phone:

Email:

Variance Details

Code Name: NFPA 13 - 2010
8.6.5.2.1.10

Conditions: Fans over 60 inches are in violation as a sprinkler obstruction.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

2

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: A shunt trip has been installed to fire alarm to shut down fans if fire alarm is activated in accordance with NFPA 13 Section 8.6.5.2.1.10.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

☒

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

☐

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: Inspector Comments: Fans over 60 inches are in violation as a sprinkler obstruction. Need to file a variance using above NFPA 13 Section 8.6.5.2.1.10 indicating a shunt trip has been installed to fire alarm to shut down fans if fire alarm is activated.