

Owner / Applicant Information

Michael Key
Crawford County Community Schools
5805 E ADMINISTRATION RD

MARENGO IN 47140

Phone 8123652135

Email MKEY@CCCS.K12.IN.US

Submitter Information

Brandon Johnson
Crawford County High School
1130 S St Rd 66

Marengo IN

Phone 8123652125

Email bjohnson@cccs.k12.in.us

Project Information

Removal of Hose Stations at Crawford County High School
1130 S St Rd 66

Marengo IN 47140

County CRAWFORD

Project Type New Addition Alteration Existing Change of Occupancy

Project Status U F=Filed U or Null=Unfiled

IDHS Issued Correction order? yes Has Violation been Issued? yes

Violation Issued by: SFM

Local Building Official

Phone: Email:

Local Fire Official

Phone: Email:

Variance Details

Code Name: 2014 IFC
901.6

Conditions: Fire hoses were installed in the gym during the time of the original build (early 1970s) when fire hydrants were not on the property.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

1

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: Fire hydrants have been added to the property, and the fire hoses are no longer needed.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: Fire hydrants have been added to the property, and the fire hoses are no longer needed. Therefore, having the fire hoses inspected and maintained is cost prohibitive since they will not be used.