

Owner / Applicant Information

Mark Merrill  
Deaconess Gateway Hospital  
4011 GATEWAY BLVD  
  
EVANSVILLE IN 47630  
Phone 8124305037  
Email MARK.MERRILL@DEACONESS.COM

Submitter Information

Roger Lehman  
RLehman & Son Consulting  
1220 N Red Bank Rd  
  
Evansville IN  
  
Phone 8125890331  
Email roger@rlehmanandson.com

Project Information

Deaconess Gateway Complex WAP for Elevators  
4011-4199 Gateway Blvd

Newburgh IN 47630

County WARRICK

Project Type New ☐ Addition ☐ Alteration ☒ Existing ☐ Change of Occupancy ☐

Project Status ☒ U F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☒ No Has Violation been Issued? ☒ No

Violation Issued by: NA

Local Building Official

Phone:  Email:

Local Fire Official

Phone:  Email:

Variance Details

Code Name: Other Code (Not in the list provided)  
In Elev Code 2.8.1 Misc Equipm

Conditions: WAP will be placed in Elevator shaft

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

1

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: The small wireless access point (WAP) device will be placed at the top of the elevator shaft. Entire Building is sprinkled per NFPA 13. Contact for security and emergency response personnel while in Elevator shaft is critical for safe operation of the Hospital. Because of the reinforced concrete and steel construction of Elevator shafts, signal for security and emergency personnel is currently not available. Small device does not present fire or elevator operation problems. Given the device is power over ethernet (PoE), low voltage connection is all that is required.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Y Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: Contact for security and emergency response personnel while in Elevator shaft is critical for safe operation of the Hospital.