Lisa Fast LISA & VERLYN FAST 5074 EAST 550 SOUTH LAFAYETTE IN 47905 Phone 6053104871							
5074 EAST 550 SOUTH LAFAYETTE IN 47905							
LAFAYETTE IN 47905							
Dhone 4052104071							
PHOTE 00051040/1							
Email LISAFASTSTAMPS@GMAIL.COM							
Submitter Information							
Patrick Grimes							
Cube & Company							
302 Ferry Street							
Lafayette IN							
Phon∈ 7652694321							
Email pgrimes@cubeandco.com							
Designer Information							
George Wahl							
The Wahl Architecture Studio, LLC							
101 North 6th Street							
LAFAYETTE IN							
Phon∈ 7654295880							
Email kurtw@wahlarch.com							
Project Information							
AGRICULTURAL EXHIBIT HALL							
5074 E 550 S							
LAFAYETTE IN 47905							
County TIPPECANOE							
Project Type New Y Addition Alteration Existing Change of Occupancy							
Project Status F = Filed U or Null=Unfiled							
IDHS Issued Correction order? Has Violation been Issued?							
IDHS Issued Correction order? Violation Issued by: NA Has Violation been Issued? NA							
IDHS Issued Correction order? Violation Issued by: NA Local Building Official							
IDHS Issued Correction order? Violation Issued by: NA Local Building Official Phone: 7654239225 Email: mwolf@tippecanoe.in.gov							
IDHS Issued Correction order? Violation Issued by: NA Local Building Official							

Variance Deta	<u>ails</u>						
Code Name:	ne: Other Code (Not in the list provided)						
	2014 IBC Table 1004.1.2						
Conditions:	The calculated occupant load per Table 1004.1.2 is over 425 persons based on 15 sf per person.						
DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:							
	1=Non-compliance with the rule will not be adverse to the public health, safety or w						
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).						
Facts:	The owners will self-impose the maximum load for the entire building to 297 persons.						
DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:							
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.						
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.						
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.						
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure						
Facts:	With only 2 exits required for the occupant load, a total of 5 code compliant exits will be required for the building. A monitored fire alarm will be installed throughout to assist with early notification and evacuation of the building						

Variance Details

Other Code (Not in the list provided) Code Name:

2014 IBC 903.2.1.2

Conditions:

A sprinkler system will not be provided in the event building and the occupant load will be limited to 297. The above code requires a fire sprinkler system when the occupant load for a Group A-2 occupancy exceeds 100 persons.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

1 2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or

welfare. Explain why alternative actions would be adequate (be specific).

Facts:

1. A monitored fire alarm with full smoke and heat detection, horn/strobes and pull stations will be installed (not required).

- Five code compliant exits will be provided out of the space (2 required).
 An adjacent pond on the property will be provided with fire department access and a dryhydrant for fire department use.
- 4. Fire extinguishers will be installed at all exits.
- 5. Similar variances have been approved in the past.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure. Y Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements. Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure	
because of excessive costs of additional or altered construction elements. Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure	
architecturally or a historically significant part of the building or structure	
The hardship is the excessive cost of installing a fire sprinkler system which would require the installation of a water storage tank and fire pump. The nearest fire hydrant to this proposis over 2 miles away. The installation of the fire alarm along with the other proposed addition will provide an adequate level of safety and cost approximately 1/5 the cost of the fire spring system.	erty ons
This is similar to 19-02-34 and 19-02-39	