Owner / Applicant Information		
Umair Kaimkhani AVC		
2100 REGENCY DR		
IRVING TX 75002		
Phon∈ 8178819584		
Email AVCBEDFORD@GMAIL.COM		
Submitter Information		
Geoff Meyer		
Meyer Enterprises		
1000 Rand Rd		
WAUCONDA IN		
Phon∈ 8475142316		
Email g5150m@msn.com		
Project Information		
AVC 6929 W 38th St		
0727 W 30111 31		
Eagle Creek IL 46214		
County MARION		
Project Type New Addition Alteration Existing Unange of Occupancy		
Project Status		
Project Status U F=Filed U or Null=Unfiled		
Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? yes		
Project Status U F=Filed U or Null=Unfiled		
Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? yes Violation Issued by: CBD Local Building Official		
Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? yes Violation Issued by: CBD Local Building Official Phone: 3174526478 Email: planreview.class1@indy.gov		
Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? yes Violation Issued by: CBD Local Building Official		
Project Status U F=Filed U or Null=Unfiled IDHS Issued Correction order? No Has Violation been Issued? yes Violation Issued by: CBD Local Building Official Phone: 3174526478 Email: planreview.class1@indy.gov Local Fire Official		

<u>Variance Details</u>		
Code Name:	2009 Indiana Electrical Code (675 IAC 17-1.8)	
	110.26(A)(1)	
Conditions:	We have an existing clearance of 34 inches of working space from existing wall to panel board location.	
DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:		
	1=Non-compliance with the rule will not be adverse to the public health, safety or w	
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).	
Facts:	Distance between both outside existing wall and interior existing plumbing wall is 3'5" with existing electric panel on outside of wall creating the 34 inches. However, wall to wall itself is well over the 36" minimum. It also was never an issue prior to any other previous inspections and does not affect any public health, safety and/or welfare at anytime.	
DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:		
Y	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.	
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.	
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.	
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure	

Same as statement above.

Facts: