

Owner / Applicant Information

David Gettinger / MSD of Perry Township

6548 ORINOCO AVE.

INDIANAPOLIS IN 46227

Phone 3177896213

Email DGETTINGER@PERRYSCHOOLS.ORG

Project Information

Southport High School  
971 E. Banta

Indianapolis 46227

County MARION

Project Type New ☐ Addition ☐ Alteration ☒ Existing ☐ Change of Occupancy ☐

Project Status ☒ F F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☐ No Has Violation been Issued? ☐ No

Violation Issued by: NA

Local Building Official

Phone:  Email:

Local Fire Official

Phone:  Email:

Variance Details

Code Name: 2014 Indiana Building Code  
903.3.1.1.1

Conditions:

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

2

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: High voltage electrical room already covered by smoke detectors should be exempt from sprinkler for safety reasons

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

☒

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

☐

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts:

I can have it sprinkled seemed dangerous for Fire dept. with high voltage and water.