

Owner / Applicant Information

JEFFERY BABB
NEURO DIAGNOSTIC INSTITUTE (DIV. OF MENTAL HEALTH AND ADDICTIONS
5435 E. 16TH ST.

INDIANAPOLIS IN 46218

Phone 5742976781

Email JEFFERY.BABB@FSSA.IN.GOV

Submitter Information

SHAWN MORGAN
KOORSEN FIRE & SECURITY INC
2719 N. ARLINGTON AVE

INDIANAPOLIS IN

Phone 3172811757

Email SHAWN.MORGAN@KOORSEN.COM

Designer Information

Derek Selke
BSA LifeStructures
9365 Counselors Row

Indianapolis IN

Phone 3178197878

Email dselke@bsalifestructures.com

Project Information

IFSSA Neurodiagnostic Institute
5435 East 16th Street

INDIANAPOLIS IN 00000

County MARION

Project Type New ☐ Addition ☐ Alteration ☐ Existing ☐ Change of Occupancy ☐

Project Status ☐ F F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☐ Has Violation been Issued? ☐ yes

Violation Issued by: SFM

Local Building Official

Phone:

Email:

Local Fire Official

Phone:

Email:

Variance Details

Code Name:

2010 EDITION NFPA 72 18.3.3.2*

Conditions:

18.3.3.2* Notification appliances used for signaling other than fire shall not have the word FIRE, or any fire symbol, in any form (i.e., stamped, imprinted, etc.) on the appliance visible to the public. Notification appliances with multiple visible elements shall be permitted to have fire markings only on those visible elements used for fire signaling.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

1

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts:

THE CODE AS PUBLISHED AND IS AMBIGUOUS AS IT PERTAINS TO THE VISUAL PORTION OF THE APPLIANCE (STROBE)
THE VISUAL PORTION OF THE APPLIANCE IS NOT ACTIVATED FOR NON FIRE NOTIFICATION EVENTS
THE AUDIBLE PORTION (SPEAKER) OF THE APPLIANCE IS THE ONLY PORTION OF THE APPLIANCE ACTIVATED FOR NON FIRE EVENTS.
APPLYING THE STANDARD OF VISUAL MARKINGS TO AN AUDIBLE APPLIANCE IS AMBIGUOUS IN NATURE.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

☐

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

☐

Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

☐

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts:

THE IMPOSITION OF THE RULE WOULD RESULT IN UNDUE HARDSHIP TO THE CLIENT (Indiana Family and Social Services Administration) IN THE EXPENSE OF REPLACING SPEAKERS TO NOT HAVE "FIRE" PRINTED ON THEM IN EXCESS OF \$30,000.00 PARTS AND EXPECTED LABOR TO COMPLY WITH THE STANDARD REGARDING VISUAL MARKINGS ON AN AUDIBLE (SPEAKER) DEVICE OR PORTION THEREOF

