Owner / Applicant Information			
James Curtis			
Wabash Landing Apartment Homes, LLC			
6930 ATRIUM BOARDWALK SOUTH, S			
INDIANAPOLIS IN 46250			
Phon∈ 3178496900			
Email JJCURTIS@SHEEHANCOMPANIES.COM			
<u>Submitter Information</u>			
Marvin Christman			
Otis Elevator Company			
6010 Corporate Way			
Indianapolis IN			
Phone 3173472015			
Email marvind.christman@otis.com			
Designer Information			
Mark Eriksson			
CSO Architects Inc.			
8830 Keystone Crossing			
Indianapolis IN			
Phon∈ 3178487800			
Email meriksson@csoinc.net			
Project Information			
Wabash Landing Apartment Extension 325 Brown St.			
323 BIOWIT St.			
WEST LAFAYETTE IN 47906			
County TIPPECANOE			
Project Type New Addition Alteration Existing Change of Occupancy			
Project Status F F=Filed U or Null=Unfiled			
IDHS Issued Correction order? No Has Violation been Issued? No			
Violation Issued by: NA			
Local Building Official			
Phone: 7657755130 Email: cspitznagle@westlafayette.in.gov			
Local Fire Official			
Phone: 7657755130 Email: tschutter@westlafayette.in.gov			

Var	iance	Detai	lς
v ai	Idiicc	Detail	J

Code Name: Other Code (Not in the list provided)

the elevator system.

ASME A17.1 2007 yr 2.18.4.2.5

Conditions:

At car speeds of 200 FPM and 350 FPM Otis utilizes as alternate technology for providing a speed reducing switch required by ASME A17.1 section 2.18.4.2.5.

Otis is using the 3rd channel (C channel) on the main encoder to provide this input into the control algorithms. The A and B channels of the encoder are used for primary/ secondary position and speed for the control system. The ¿C¿ channel is utilized presently as a redundant check for the A and B channels and as an independent speed methodology to provide the ETSD (2.25.4.2) function, A17 required. The ETSD input is a designated electrical protective device.

The manual reset will be provided via the same reset switch as the uncontrolled motion reset switch.

There are two (2) GEN2 elevators on this project. Otis machine numbers 648005 and 648006.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

	1=Non-compliance with the rule will not be adverse to the public health, safety or w
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).
Facts:	The Gen 2 at 200 system is designed to be compliant with A17.1 ¿ 2007 with exception of components such as the alternate speed reducing switch technology which has A17.7 (AECO) approval.
DEMONS	STRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure
Facts:	The speed reducing switch is essentially to being able to use the GEN2 machine-roomless

technology. An overhead traction elevator could add an additional 50% to the overall cost of

Code Name:	Other Code (Not in the list provided)				
	ASME A17.1 2007 yr 2.18.5.1				
Conditions:	Governor Rope Diameter This GEN2 installation will utilize a 6.3 mm (1/4") diameter governor rope. This project will consist of two (2) GEN2 elevator. Otis machine number 648005 and 648006.				
DEMOI	NSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:				
	1=Non-compliance with the rule will not be adverse to the public health, safety or w				
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).				
Facts:	The 6.3 mm (1/4") rope is covered under the ASME A17.1-2010/CSA B44-2010 Code. Otis has also obtained AECO approval for the component for those Jurisdictions that have not currently upgraded to the latest Code.				
DEMONS	TRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:				
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.				
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.				
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.				
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure				
Facts:	The GEN2 underslung product has only been designed to accommodate the use of a 6.3 mm (1/4") governor rope. It would not be possible to utilize a 3/8" governor rope on this system. Switching to a different product type to accommodate the governor rope would add over 40% to the elevator cost.				
Variance Deta	<u>ils</u>				
Code Name:	Other Code (Not in the list provided)				
	ASME A17.1 2007 yr 2.22.1.1				
Conditions:	2.22.1.1 Type of Buffers For the use of ACLA buffers in place of spring buffers.				
	There are two (2) GEN2 elevator on this project. Otis machine number 648005 and 648006.				
DEMOI	NSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:				
	1=Non-compliance with the rule will not be adverse to the public health, safety or w				
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).				
Facts:	1) ACLA has had the buffers approved under the A17.7 Code by the Lift Institute. Based on the AECO approval of the ACLA buffers, Otis is requesting a variance of the buffer under the "or equivalent" wording in the Code. The speed of the elevator at 200 feet per minute and less does not utilize "C" type safeties as described in 2.22.1.1.1 and 2.22.1.3.				

Variance Details

	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure
Facts:	Otis has made a significant engineering investment in applying GEN2 machine-roomless technology at the car speeds and rises typically associated with hydraulic elevator applications. The use of the ACLA buffer at speeds of 200 feet per minute and less is one of the ways engineering has provided an equivalent product to the spring buffer and also reduce the overall cost to the building owner.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Variance Deta	aile
Code Name:	Other Code (Not in the list provided)
Code Name.	ASME A17.1 2007 yr 2.20.1
Conditions:	2.20.1 Suspension Means Steel Coated Belts (Suspension Means) Otis machine number 648005 will utilize(4)43kN Steel Coated Belts as the suspension means. Otis machine number 648006 will utilize (4) 43kN Steel Coated Belts as the suspension means.
DEMO	NSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:
	1=Non-compliance with the rule will not be adverse to the public health, safety or w
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).
Facts:	 All aspects of the belts, terminations and monitoring system are fully compliant with the ASME A17.1-2010 edition of the code. Otis will install a permanent belt monitoring device on this GEN2 elevator.
<u>DEMONS</u>	STRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Coated Steel Belts are an essential component of the Otis machine-roomless configuration of the GEN2 traction elevator. The belt allows for the use of a much smaller diameter drive sheave. The GEN2 machine-roomless system could not be reconfigured to use steel cables. Changing to an overhead traction machine would add significant costs to the elevator and building construction. The elevator cost would increase over 30%, and the building would require the construction of an overhead penthouse.

Imposition of the rule would prevent the preservation of an

Facts:

architecturally or a historically significant part of the building or structure