

Owner / Applicant Information

Sarah Galloway
Shiel Sexton Company, Inc.
902 N CAPITOL AVENUE

INDIANAPOLIS IN 46204

Phone 3174236226

Email SGALLOWAY@SHIELSEXTON.COM

Submitter Information

Sarah Galloway
Shiel Sexton Company, Inc.
902 N Capitol Avenue

INDIANAPOLIS IN

Phone 3174236226

Email sgalloway@shielsexton.com

Designer Information

Ray Rebilas
Kitchen and Associates
756 Haddon Ave

Collingswood NJ

Phone 8565592065

Email rrebilas@kitchenandassociates.com

Project Information

Oasis at 56th Street
4940 W 56th St

Indianapolis IN 46254

County MARION

Project Type New ☒ Addition ☐ Alteration ☐ Existing ☐ Change of Occupancy ☐

Project Status ☒ F F=Filed U or Null=Unfiled

IDHS Issued Correction order? ☐ Has Violation been Issued? ☐

Violation Issued by: NA

Local Building Official

Phone:

Email:

Local Fire Official

Phone:

Email:

Variance Details

Code Name: Other Code (Not in the list provided)
NFPA 24, 1995, Section 3-3.2

Conditions: The PIV is located too close to building.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

- 1

1=Non-compliance with the rule will not be adverse to the public health, safety or w
- 2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: The currently location will not affect public health, safety or welfare.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

- Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.
- Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.
- Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.
- Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: After discussion with local fire marshal, the proposed relocation would still be in violation of the code.