| Owner / Applicant Information   |  |  |
|---|--|--|
| Hetal V Patel   |  |  |
| Richland Suites Inc   |  |  |
| 1751 N STONELAKE DR   |  |  |
|   |  |  |
| BLOOMINGTON IN 47404  |  |  |
| Phon∈ 8123604426  |  |  |
| Email HETAL@BLOOMHOTELS.NET   |  |  |
| Submitter Information   |  |  |
| Michael Houseman  |  |  |
| Brown Sprinkler   |  |  |
| 5250 Commerce Circle  |  |  |
| Indianapolis IN   |  |  |
| Phon∈ 3178894225  |  |  |
| Email mikehouseman@brownsprinkler.com                                     |  |  |
|   |  |  |
| <u>Project Information</u>  |  |  |
| LaQuinta Inn and Suites   |  |  |
| 3380 W Runkle Way   |  |  |
| BLOOMINGTON IN 00000  |  |  |
| County MONROE   |  |  |
| Project Type New Addition Alteration Existing Change of Occupancy         |  |  |
| Project Status F F=Filed U or Null=Unfiled                                |  |  |
|   |  |  |
|   |  |  |
| Violation Issued by: LFD  |  |  |
| Local Building Official   |  |  |
| Phone: 8123492581 Email: jgerstbauer@co.monroe.in.us  Local Fire Official |  |  |
| Phone: 8123492581 Email: clappt@bloomington.in.gov                        |  |  |
|   |  |  |
|   |  |  |

| <u>Variance Details</u>  |  |  |
|--|--|--|
| Code Name:   | Other Code (Not in the list provided)  |  |
|  | 905.4  |  |
| Conditions:  | Hose Valves are located on the floor landing   |  |
| DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:   |  |  |
|  | 1=Non-compliance with the rule will not be adverse to the public health, safety or w   |  |
| 1  | 2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific). |  |
| Facts:   | The hose valves are located on each floor landing in each stairwell. They are located in a way that will not impede the fire department access.  |  |
| DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE: |  |  |
| Υ  | Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.  |  |
|  | Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.   |  |
|  | Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.   |  |
|  | Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure  |  |

Facts: