Owner / Applicant Information		
Hetal V Patel		
Richland Suites Inc		
1751 N STONELAKE DR		
BLOOMINGTON IN 47404		
Phone 8123604426		
Email HETAL@BLOOMHOTELS.NET		
Submitter Information		
Michael Houseman		
Brown Sprinkler		
5250 Commerce Circle		
Indianapolis IN		
Phone 3178894225		
Email mikehouseman@brownsprinkler.com		
Project Information		
LaQuinta Inn and Suites		
3380 W Runkle Way		
BLOOMINGTON IN 00000		
County MONROE		
Project Type New Addition Alteration Existing Change of Occupancy		
Project Status F F=Filed U or Null=Unfiled		
IDHS Issued Correction order? No Has Violation been Issued? yes		
Violation Issued by: LFD		
Local Building Official		
Phone: 8123492581 Email: jgerstbauer@co.monroe.in.us		
Local Fire Official Phone: 8123492581 Email: clappt@bloomington.in.gov		
ciapptebiotinington.in.gov		

Variance Details

Code Name:	Other Code (Not in the list provided)	
	905.4	
Conditions:	Hose Valves are located on the floor landing	
DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:		
	1=Non-compliance with the rule will not be adverse to the public health, safety or w	
1	2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).	
Facts:	The hose valves are located on each floor landing in each stairwell. They are located in a way that will not impede the fire department access.	
DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:		
Υ	Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.	
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.	
	Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.	
	Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure	
Facts:		