

Owner / Applicant Information

Jake M Quenzler  
9450 Mississippi  
9450 MISSISSIPPI

MERRILLVILLE IN 46410

Phone 2196145000

Email JAKE.QUENZLER@YAHOO.COM

Project Information

Big Concrete and Excavating  
9450 Mississippi

Merrillville 46410

County LAKE

Project Type New  Addition  Alteration  Existing  Change of Occupancy

Project Status  F=Filed U or Null=Unfiled

IDHS Issued Correction order?  No Has Violation been Issued?  No

Violation Issued by: NA

Local Building Official

Phone:  Email:

Local Fire Official

Phone:  Email:

Variance Details

Code Name:

Conditions:

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

.....

1

1=Non-compliance with the rule will not be adverse to the public health, safety or welfare.

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts:

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts:

Variance Details

Code Name: Other Code (Not in the list provided)

2014 IBC, 903.2.9

Conditions: 903.2.5 Group S-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group

S-1 occupancy where one of the following conditions exists:

1. A Group S-1 fire area exceeds 12,000 square feet (1115 m2 ) .
2. A Group S-1 fire area is located more than three stories above grade plane.
3. The combined area of all Group S-1 fire areas on all floors, including any mezzanines, exceeds 24,000 square feet (2230 m2 ) .
4. A Group S-1 fire area used for the storage of commercial trucks or buses where the fire area exceeds 5,000 square feet (464 m2 ) .

No commercial trucks will be parked inside of the building. Only allowing loading and unloading in the structure. Short term and long term parking will be in the parking lot.

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or welfare.

2

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: The property is located 650 sq ft from a fire hydrant, additionally, exit signs, smoke detectors, fire extinguishers and alarm monitoring service will be engaged.

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure.

Facts: Cost to install sprinkler system more than \$35,000.0

