Owner / Applicant Information

Josh Schmitt
The Hoosier Electrician
7469 WEST U.S. HIGHWAY 36

COATESVILLE IN 46121

Phone 3176812616

Email THEHOOSIERELECTRICIAN18@GMAIL.COM

Project Information

carmel stove oultets
12951 grenville street

carmel 46032

County HAMILTON

Project Type New [ ] Addition [ ] Alteration [ ] Existing [ ] Change of Occupancy [ ]

Project Status [F] F=Filed U or Null=Unfiled

IDHS Issued Correction order? [ ] Has Violation been Issued? [ ]

Violation Issued by: NA

Local Building Official

Phone: 3177731282 Email: whohlt@carmel.in.gov

Local Fire Official

Phone: 3177731282 Email: cfdinfo@carmel.in.gov

Variance Details

Code Name:

2009 NEC 210.52 (c)

Conditions: outlets on stove counter top are 29 inches instead of the 24 inches allowed by code

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1=Non-compliance with the rule will not be adverse to the public health, safety or w

1= Non-compliance with the rule will not be adverse to the public health, safety or w

1

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts: having the outlets more than 24 inches will not affect heath or welfare of the public

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

☐ Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

☐ Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Y Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

☐ Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: we would have to tear down and replace a 8 foot long 3.5 foot high piece of granite thats being used as the back splash.